



DEPARTMENT OF ENVIRONMENTAL PROTECTION

Marc Elrich
County Executive

Adam Ortiz
Director

November 4, 2019

Mr. Joe Bergmeister
Whiting-Turner Contracting Company
6305 Ivy Lane
Greenbelt, MD 20770

Re: Noise Suppression Plan for Installation of Piles and Soil Excavation at HarborChase Rockville, 55 West Gude Drive, Rockville

Dear Mr. Bergmeister:

This letter is to acknowledge receipt of the Noise Suppression Plan (NSP) submitted to the Montgomery County Department of Environmental Protection (DEP) dated October 14, 2019, for installation of piles and excavation of soil at 55 West Gude Drive, Rockville.

We have completed our review of the plan and found it to be sufficient and approve this plan with the following terms and conditions:

1. This approval is specific to only the noise created from drilling activities related to the installation of piles, lagging boards, and tie-back system, and loading and hauling of excavated material.
2. A hydraulic vibratory driver/extractor shall be used for installation of the piles.
3. The 85 A-Weighted decibel (dBA) limit only applies from 7:00 a.m. until 5:00 p.m., Monday through Friday for the activities specified in item 1 above. At all other times, including weekday Federal holidays, the maximum noise levels must comply with the noise limits as specified in Section 31B-6 of the Montgomery County Code.
4. Where possible, schedule the more noise intensive activities for less intrusive times, such as mid-morning to mid-afternoon.
5. Noise mitigation barriers should be erected around loud pieces of stationary machinery (e.g., generators, concrete pumps, etc.).
6. Construction equipment shall be equipped with well-maintained and effective mufflers and moving parts shall be well lubricated to avoid unnecessary noise from squeaking parts. Equipment access doors and hatches should remain closed when the units are in operation and all equipment should be operated at the minimum level necessary to get the job done. Minimize banging, clattering, buzzing and other annoying types of noises.
7. Slamming of tailgates and dropping of materials into empty trucks are prohibited. Advise all onsite staff, including delivery and dump truck drivers of noise mitigation procedures prior to work.
8. Avoid unnecessary backing of equipment and trucks with tonal back-up alarms. Configure the site to maximize forward movement. Consider using lawful alternatives to factory pre-set backup alarms, such as flagpersons or white noise backup alarms.
9. Where possible, use the local power grid to reduce the use of generators and internal combustion powered tools.


255 Rockville Pike, Suite 120 • Rockville, Maryland 20850 • 240-777-0311
www.montgomerycountymd.gov/dep

Mr. Joe Bergmeister
Noise Suppression Plan – HarborChase
November 4, 2019
Page 2 of 2

10. Avoid prolonged idling of equipment. If equipment is not utilized for long periods, operator should shut off equipment to reduce idling noise.
11. Communicate frequently with nearby residential and commercial buildings so they are aware of the work schedule and expected construction activities.
12. Noise levels will be monitored on a regular basis with the decibel levels and locations of the monitoring sites kept in a log on site, which shall be available for inspection and review upon request.
13. You must maintain a log on site containing detailed information concerning any complaints received regarding noise from this project.
14. DEP may suspend, modify or revoke this approval for any violation of the terms and conditions of the Noise Suppression Plan.
15. A copy of this approval and the Noise Suppression Plan must be available at the construction site.

If you have any questions regarding this matter, please contact Gretchen Ekstrom at 240-777-7750 or by email at Gretchen.Ekstrom@MontgomeryCountyMD.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "Adam Ortiz", with the letters "FOL" written below it.

Adam Ortiz, Director
Montgomery County DEP

cc: Bridget Newton, Rockville City Mayor
Victor Brito, Rockville City Police Chief
Ken Hartman, BCC Regional Services Center
Derrick Harrigan, BCC Regional Services Center
MC Police, 1st District Station, Rockville
Stan Edwards, MC DEP
Steve Martin, MC DEP